



Comment Summary

Application #: PL201700099

Address: 8200 28th Avenue South, Bloomington, MN 55425

Request: **Minor Revision to Final Development Plans for a temporary wireless communications tower for a special event.**

Planning Review Contact: Nick Johnson at nmjohnson@BloomingtonMN.gov, (952) 563-8925

- 1) Prior to the erection of the temporary wireless communications tower, the applicant must complete a 7460 airspace analysis of the proposed temporary tower with the Federal Aviation Administration.
- 2) All fencing erected must comply with Section 21.301.08 of the City Code.

Building Department Review Contact: Duke Johnson at djohnson@BloomingtonMN.gov, (952) 563-8959

- 1) All antennas must meet 90MPH wind rating as per 2015 MN Building code
- 2) Separate Electrical permit will be required