



## Comment Summary

**Application #:** PL201800003

**Address:** 3200 E 81ST ST, BLOOMINGTON, MN 55425

**Request:** **Minor Revision to Final Development Plan for a seasonal vestibule from October to March**

---

**Building Department Review Contact:** Duke Johnson at [djohnson@BloomingtonMN.gov](mailto:djohnson@BloomingtonMN.gov), (952) 563-8959

- 1) Building permit required.

**Fire Department Review Contact:** Laura McCarthy at [lmccarthy@BloomingtonMN.gov](mailto:lmccarthy@BloomingtonMN.gov), (952) 563-8965

- 1) Applicant to provide certificate or letter from the manufacturer showing the flame retardant rating of the material.