



Comment Summary

Application #: PL201700199

Address: 8201 24th Avenue South, Bloomington, MN 55425
8000 24th Avenue South, Bloomington, MN 55425

Request: **Minor Revision to Final Development Plans for six small cell wireless installations on existing light poles.**

Planning Review Contact: Nick Johnson at nmjohnson@BloomingtonMN.gov, (952) 563-8925

- 1) How will the shroud design affect the light levels of the replacement poles? Lighting levels for parking areas must meet Code or existing levels of illumination. No further degradation of lighting beyond existing condition is permitted. Photometric plans may be required to be submitted for review prior to issuance of building/electrical permits.
- 2) Temporary lighting on future development sites (8000 and 8201 24th Ave South) must be replaced with Code-compliant lighting per Section 21.301.07 upon redevelopment of those sites.

Building Department Review Contact: Duke Johnson at djohnson@BloomingtonMN.gov, (952) 563-8959

- 1) Electrical permit required by licensed State of MN Electrical contractor.
- 2) Building permit required.

Utility Review Contact: Jen Desrude at jdesrude@BloomingtonMN.gov, (952) 563-4862

- 1) Submit plans for any utility line installation feeding power or fiber to the new antennas for City review, approval and ROW Permits.