



Comment Summary

Application #: PL201800292

Address: 8801 Lyndale Avenue South, Bloomington, MN 55420

Request: **Minor Revision to Final Site and Building Plans to add antennas to an existing monopole tower.**

NOTE: All comments are not listed below. Please review all plans for additional or repeated comments.

Planning Review Contact: Nick Johnson at nmjohnson@BloomingtonMN.gov, (952) 563-8925

- 1) Section 19.63.05(q) of the City Code requires that the visual impact of antennas and mounts be minimized. The proposed design does not minimize visual impact, as there are six unused mounts, necessitating a "crow's nest" design. This type of design has been determined to not minimize visual impact. Please revise the design to minimize visual impact.
- 2) Please confirm that existing antennas are not being modified and that the height of existing equipment is not increasing beyond the existing condition. Imagery of the existing tower does not match the elevation drawing.