

Mr. Michael Centinario  
Planner  
City of Bloomington  
1800 West Old Shakopee Road  
Bloomington, MN 55431

April 13, 2018

Re: Final Plat Review – Legacy Addition (Hyatt House) *(Received 04/09/18)*  
Northeast corner of 86<sup>th</sup> Street East and Old Shakopee Road (County State Aid Highway 1)  
Hennepin County Plat Review ID #3686 *(Reviewed 04/10/18)*  
*Redevelops vacant 4.6 acres into a 150 room Hyatt House Hotel*

Dear Mr. Centinario:

Please consider the following in your review of this proposal:

## Access

In addition to a single access along 86<sup>th</sup> Street, this plat proposes a single access along Old Shakopee Road approximately 650 feet north of the intersection with 86<sup>th</sup> Street. As part of an on-going effort to reduce vehicle conflicts on four-lane roadways, we envision the future condition having a raised concrete median along the centerline of this segment of Old Shakopee Road, thus restricting any and all access to right-in/right-out only.

## Requirements

To enhance safety and mobility along this segment, the access needs to be relocated to the north (at least 150 feet). This would not only improve access spacing (mid-block between intersections – 750 feet), but would also allow for additional room for acceleration of northbound vehicles entering Old Shakopee Road from 86<sup>th</sup> Street.

Until a complete median can be constructed by Hennepin County we believe it necessary to limit this proposed access in one of the following manners:

- Move the driveway to the north end of the site to align with the existing median – further extension of the existing median to the south will likely be necessary – this is our preferred option.
- As part of the development work, construct a median at the mid-block location referenced above significant enough to restrict any potential illegal maneuvers – if impacting access on the west side, the applicant will need to work with the city
- If this access is not protected by either an existing or constructed median, we may consider an alternative right-in/right-out access design to be reviewed by county staff

## Right-of-Way

### Requests

To allow for our typical four-lane divided section with off-road trail we are requesting dedication necessary for a consistent 60 feet of right-of-way along this section of Old Shakopee Road. If this cannot be reasonably provided for, we will accept an easement beyond 50 feet from the centerline to include drainage and utility as well as sidewalk and trail.

## Additional Considerations

### Requirements

Installation of both Americans with Disabilities Act (ADA) compliant pedestrian ramps and Accessible Pedestrian Signals (APS) will be necessary at the intersection of Old Shakopee Road and 86<sup>th</sup> Street. This will include the 'porkchop' or raised concrete island. We routinely expect this work to be completed by any new developments abutting a signalized intersection.

Any proposed plantings along the boulevard of Old Shakopee Road will need to be setback a minimum of six feet from the back of the curb.

## Storm Water and Drainage

### Requirements

Please ensure discharge rates remain less than existing flow rates. The county storm water system will not take water from new drainage areas. Additional treatments may be necessary if flow rates cannot match existing.

Storm water and drainage questions can be directed to Drew McGovern at 612-596-0208, drew.mcgovern@hennepin.us.

## Permits

### Requirements

Please inform the developer that all construction within county right-of-way requires an approved Hennepin County permit prior to beginning construction. This includes, but is not limited to, driveway and street access, drainage and utility construction, trail development, and landscaping.


Permit questions can be directed to Michael Olmstead at 612-596-0336, michael.olmstead@hennepin.us.

## More information

Please contact us for any further discussion of these items.

- Bob Byers at 612-596-0354, robert.byers@hennepin.us
- Jason Gottfried at 612-596-0394, jason.gottfried@hennepin.us

Sincerely,



Chad Ellos, PE

Transportation Planning Division Manager



# Hennepin County Property Map

PL201800123  
PL2018-123  
Hyatt House  
2301 E Old Shakopee  
Date: 4/12/2018



PARCEL ID: 2111923340002

OWNER NAME: Gene H & Elizabeth Kissner

PARCEL ADDRESS: 52 Address Unassigned,  
Corcoran MN 00000

PARCEL AREA: 16.15 acres, 703,607 sq ft

A-T-B: Abstract

SALE PRICE:

SALE DATA:

SALE CODE:

ASSESSED 2017, PAYABLE 2018

PROPERTY TYPE: Farm  
HOMESTEAD: Homestead  
MARKET VALUE: \$51,800  
TAX TOTAL: \$261.30


ASSESSED 2018, PAYABLE 2019

PROPERTY TYPE: Farm  
HOMESTEAD: Homestead  
MARKET VALUE: \$52,000

## Comments:

This data (i) is furnished 'AS IS' with no representation as to completeness or accuracy; (ii) is furnished with no warranty of any kind; and (iii) is not suitable for legal, engineering or surveying purposes. Hennepin County shall not be liable for any damage, injury or loss resulting from this data.

COPYRIGHT © HENNEPIN  
COUNTY 2018

[illegible][illegible][illegible][illegible][illegible]