

## Centinario, Michael

---

**To:** Centinario, Michael  
**Subject:** RE: 415 E 78TH ST

**From:** Centinario, Michael  
**Sent:** Thursday, December 3, 2020 10:31 AM  
**To:** 'Jose Becerra' <ybconstructionmn@gmail.com>  
**Cc:** Miller, Tim <tmiller@BloomingtonMN.gov>  
**Subject:** RE: 415 E 78TH ST

Hi Jose,

I signed off on the Electrical Permit and added the wallpack to the permit file. Please ensure the wallpacks are installed at 90-degrees, which is a Code requirement.

We'll need to complete a nighttime lighting inspection to confirm there is enough light at entrances. The minimum requirement is 7 footcandles at the primary entrance and 2 footcandles at other entrances. You may want to invest in a light meter to inspect yourself before calling for an exterior lighting inspection – if the entrances do not meet the minimum, you will need to add lighting, which could delay your C/O.

Also, the parking lot is woefully deficient of lighting. While retrofitting lighting in the parking lot is not a requirement for this remodel, **we strongly recommend** that the parking lot be brought up to current lighting standards. Insufficient lighting is a safety concern! We are happy to discuss and review a parking lot lighting plan in hopefully not-too-distant future.

Thank you,  
Mike



**MICHAEL CENTINARIO** | Planner  
**PH:** 952-563-8921 **EMAIL:** [mcentinario@bloomingtonmn.gov](mailto:mcentinario@bloomingtonmn.gov)  
1800 West Old Shakopee Road, Bloomington, MN 55431

[CONFIDENTIALITY AND PRIVACY NOTICE] Information transmitted by this email is proprietary to the City of Bloomington and is intended for use only by the individual or entity to which it is addressed, and may contain information that is private, privileged, confidential or exempt from disclosure under applicable law. If you are not the intended recipient or it appears that this mail has been forwarded to you without proper authority, you are notified that any use or dissemination of this information in any manner is strictly prohibited. In such cases, please delete this mail from your records. If you received this communication in error, please notify me promptly.