

May 20, 2021

**Londell Pease**

Senior Planner

City of Bloomington Minnesota  
1800 West Old Shakopee Road  
Bloomington, Minnesota 55431-3027

Re: Independent School District #271  
Jefferson-Olson Mechanical Plant  
Re: Permit Application No. PRBD202104233  
Commission No. 202115

Dear Londell:

The above mentioned project includes the installation of two chillers and evaporative cooling tower to provide a central cooling plant for Olson Elementary School, Olson Middle School, and Jefferson High School. As requested, we have performed a noise impact study to demonstrate compliance with Ordinance No. 2016-8, Article IV: Noise Code, section 10.29.02.

Attachment 1 is a site plan showing the location of the proposed chiller building and cooling towers in relation to the neighboring properties.


Attachment 2 contains the product data for the basis-of-design cooling towers that will be located on the roof as shown on the site diagram. The sound power levels included in this product data were used in Attachment 3 to calculate the A-weighted sound pressure level at the property line in dBA.

Attachment 3 contains sound analysis at the property line for one cooling tower in operation, two cooling towers in simultaneous operation, and four cooling towers in simultaneous operation. The sound analysis was performed with a distance of 300 feet between the new chiller building and the property line as shown in Attachment 1.

As stated above, the proposed chiller building will include installation of two cooling towers. The chiller building includes space for two additional cooling towers to be installed in the future when all buildings are connected to the new chilled water plant. Upon completion of this project, two cooling towers operating at peak capacity would result in 50 dBA at the residential property line. When the chiller plant is connected to all buildings in the future, two additional cooling towers will be in operation. All four cooling towers operating at peak capacity would result in 52 dBA at the residential property line.

**Wold Architects and Engineers**  
332 Minnesota Street, Suite W2000  
Saint Paul, MN 55101  
woldae.com | 651 227 7773

**PLANNERS  
ARCHITECTS  
ENGINEERS**



Since the cooling towers are only in operation when temperatures are warm enough to require mechanical cooling in the building HVAC systems, the chiller plant will mostly be in operation from May through September. A significant portion of the time the plant is in operation, it will not be operating at full capacity. Outside air temperature and occupancy levels will frequently only require that one of the cooling towers is in operation. One cooling tower operating at peak capacity would result in 46 dBA at the residential property line. We understand that all four cooling towers running simultaneously would exceed the residential sound level that goes into effect at 10:00 p.m., however based on the occupancy and expected cooling demand that late at night, we would expect that at most two cooling towers would be in operation at night. In most cases one or none of the cooling towers would be in operation after 10:00 p.m. Overnight, the cooling towers would typically be off to conserve energy except on very warm nights.

We hope this study provides adequate information to satisfy Ordinance No. 2016-8, Article IV: Noise Code, section 10.29.04. Feel free to contact me directly with any additional questions relating to this noise impact study.

Sincerely,

Wold Architects and Engineers



A handwritten signature in black ink, appearing to read "Kyle Edsten". The signature is fluid and cursive, with the first name "Kyle" and last name "Edsten" clearly distinguishable.

Kyle Edsten | P.E.  
Associate

Enclosures

cc: Tim Rybak, ISD#761  
Kent Kenry, KA  
Andrew Dahlquist, Wold  
Patrick Triggs, Wold  
Joseph Matlock, Wold  
Noa Nelson, Wold

LW/ISD\_271/202115/crsp/may21



**FOR REFERENCE ONLY  
NOT FOR CONSTRUCTION**





## Baltimore Aircoil Company Cooling Tower Selection Report

Version: 8.11.0 NA  
Product data correct as of: October 15, 2020

Project Name: ISD 271  
Selection Name: 1222 - 40hp  
Project State/Province: Minnesota  
Project Country: United States  
Date: October 23, 2020

### Model Information

Product Line: Series 3000  
Model: S3E-1222-07P  
Number of Units: 1  
Fan Type: Standard Fan  
Fan Motor: (1) 40.00 = 40.00 HP/Unit  
Total Standard Fan Power: Full Speed, 40.00 BHP/Unit  
IBC 2018 Code Compliance: No  
California OSHPD Project: No  
Special Seismic Certification: No  
Intake Option: None  
Internal Option: None  
Discharge Option: None

### Design Conditions

Flow Rate: 1,800.00 USGPM  
Hot Water Temp.: 95.00 °F  
Cold Water Temp.: 85.00 °F  
Wet Bulb Temp.: 78.00 °F  
Tower Pumping Head: 4.91 psi  
Reserve Capability: 1.23 %  
Heat Rejection: 8,996,400 BTUH

**Thermal performance at design conditions and standard total fan motor power is certified by the Cooling Technology Institute (CTI).**

### Engineering Data, per Unit

Unit Length: 11' 09.75"  
Unit Width: 21' 06.50"  
Unit Height: 12' 03.00"  
Air Flow: 149,530 CFM  
Approximate Shipping Weight: 12,330 pounds  
Heaviest Section: 12,330 pounds  
Approximate Operating Weight: 25,360 pounds  
Heater kW Data (Optional)  
0°F (-17.8°C) Ambient Heaters: (2) 10 kW  
-20°F (-28.9°C) Ambient Heaters: (2) 14 kW


Minimum Distance Required for Single Unit:  
(For multiple units, refer to Layout Guidelines)

From Solid Wall: 6.5 ft.  
From 50% Open Wall: 3 ft.

### Energy Rating:

54.58 per ASHRAE 90.1, ASHRAE 189 and CA Title 24.

Note: These unit weights and dimensions account for the selected fan type for the standard cataloged drive configuration, but they do not account for other options/accessories. Please contact your local BAC sales representative for weights and dimensions of units with other options/accessories.





# Baltimore Aircoil Company Cooling Tower Selection Report

Version: 8.11.0 NA  
Product data correct as of: October 15, 2020

Project Name: ISD 271  
Selection Name: 1222 - 40hp  
Project State/Province: Minnesota  
Project Country: United States  
Date: October 23, 2020

## Model & Fan Motor

Product Line: Series 3000  
Model: S3E-1222-07P  
Number of Units: 1  
Fan Motor: (1) 40.00 = 40.00 HP/Unit  
Total Standard Fan Power: Full Speed, 40.00 BHP/Unit

## Model Accessories and Code Compliance

IBC 2018 Code Compliance: No  
California OSHPD Project: No  
Special Seismic Certification: No  
Intake Option: None  
Internal Option: None  
Discharge Option: None  
Fan Type: Standard Fan


## Design Conditions @ Standard Total Fan Motor Power per Unit (40.00 HP)

Thermal performance at design conditions and standard total fan motor power is certified by the Cooling Technology Institute (CTI).

Flow Rate: 1,800.00 USGPM  
Hot Water Temp.: 95.00 °F  
Cold Water Temp.: 85.00 °F  
Wet Bulb Temp.: 78.00 °F  
Heat Rejection: 8,996,400 BTUH

Predicted Performance

Fan Motor Alternative = Full Speed, 40.00 BHP  
Flow Rate = 1800.00 USGPM (100.00% of Design)



Warning	Applies to Design Conditions	Applies to OffDesign Conditions
1. One or more selection parameters are outside of CTI Certification limits.	No	Yes



# Baltimore Aircoil Company Cooling Tower Selection Report

Version: 8.11.0 NA  
Product data correct as of: October 15, 2020

Project Name: ISD 271  
Selection Name: 1222 - 40hp  
Project State/Province: Minnesota  
Project Country: United States  
Date: October 23, 2020

## Model Information

Product Line: Series 3000  
Model: S3E-1222-07P  
Number of Units: 1  
Fan Type: Standard Fan  
Fan Motor: (1) 40.00 = 40.00 HP/Unit


IBC 2018 Code Compliance: No  
California OSHPD Project: No  
Special Seismic Certification: No  
Intake Option: None  
Internal Option: None  
Discharge Option: None

Total Standard Fan Power: Full Speed, 40.00 BHP/Unit

Octave band and A-weighted sound pressure levels (Lp) are expressed in decibels (dB) reference 0.0002 microbar. Sound power levels (Lw) are expressed in decibels (dB) reference one picowatt. Octave band 1 has a center frequency of 63 Hertz.

Top Sound Pressure (dB)		
Octave Band	Distance	
	5 ft.	50 ft.
1	86	74
2	86	75
3	85	74
4	82	68
5	79	64
6	73	59
7	69	55
8	67	52
A-wgtd	84	71

Air Inlet Sound Pressure (dB)		
Octave Band	Distance	
	5 ft.	50 ft.
1	82	68
2	84	67
3	82	70
4	76	66
5	69	61
6	63	52
7	58	46
8	55	43
A-wgtd	78	67



End Sound Pressure (dB)		
Octave Band	Distance	
	5 ft.	50 ft.
1	79	72
2	79	67
3	77	68
4	70	63
5	65	58
6	58	49
7	51	44
8	48	39
A-wgtd	73	64

End Sound Pressure (dB)		
Octave Band	Distance	
	5 ft.	50 ft.
1	79	72
2	79	67
3	77	68
4	70	63
5	65	58
6	58	49
7	51	44
8	48	39
A-wgtd	73	64

Total Sound Power (dB)		
Octave Band	Center Frequency (Hertz)	Lw
1	63	106
2	125	107
3	250	106
4	500	100
5	1000	96
6	2000	91
7	4000	87
8	8000	84
A-wgtd		102

Air Inlet Sound Pressure (dB)		
Octave Band	Distance	
	5 ft.	50 ft.
1	82	68
2	84	67
3	82	70
4	76	66
5	69	61
6	63	52
7	58	46
8	55	43
A-wgtd	78	67

**Note:** The use of frequency inverters (variable frequency drives) can increase sound levels.  
**Extra Notes:** Sound data provided by CTI ATC-128 sound test code revision 2019

COOLING TOWERS CT-1, CT-2, CT-3, AND CT-4 ACTIVE NORTH OF 102ND STREET. REFER TO ATTACHED SURVEY.

Selected Sum or Path Report

Project Name:  
Location:  
Building Owner:  
Project ID:

Sum 1

Element	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	Comments
Path2	52	53	51	45	39	33	27	
Path1	52	53	51	44	39	32	26	
Path3	51	52	50	43	38	31	25	
Path4	51	52	50	43	37	30	24	
Sum	57	58	56	50	44	38	32	
NC 47	RC 44(N)		52 dBA					

COOLING TOWERS CT-1, AND CT-2 ACTIVE NORTH OF 102ND STREET. REFER TO ATTACHED SURVEY.

## Selected Sum or Path Report

Project Name:

Location:

Building Owner:

Project ID:

**Sum 1**

<u>Element</u>	<u>63Hz</u>	<u>125Hz</u>	<u>250Hz</u>	<u>500Hz</u>	<u>1KHz</u>	<u>2KHz</u>	<u>4KHz</u>	<u>Comments</u>
----------------	-------------	--------------	--------------	--------------	-------------	-------------	-------------	-----------------

Path2	52	53	51	44	39	32	26	
Path1	52	53	51	45	39	33	27	
<b>Sum</b>	<b>55</b>	<b>56</b>	<b>54</b>	<b>48</b>	<b>42</b>	<b>36</b>	<b>30</b>	

<b>NC 45</b>	<b>RC 42(N)</b>	<b>50 dBA</b>						
--------------	-----------------	---------------	--	--	--	--	--	--



COOLING TOWER CT-1 ACTIVE NORTH OF 102ND STREET. REFER TO ATTACHED SURVEY.

Selected Sum or Path Report

Project Name:  
Location:  
Building Owner:  
Project ID:

Sum 1

Element	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	Comments
Path2	52	53	51	44	39	32	26	
Sum	52	53	51	44	39	32	26	
NC 41	RC 38(N)		46 dBA					

COOLING TOWERS CT-1, CT-2, CT-3, AND CT-4 ACTIVE NORTH OF 102ND STREET.

## Paths Report

Project Name:

Location:

Building Owner:

Project ID:

### Path2

Element	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	Comments
Custom Element	106	107	106	100	96	91	87	
Outdoor	-49	-49	-49	-49	-49	-49	-49	CT-1
Barrier	-5	-5	-6	-6	-8	-9	-11	Barrier insertion loss
<b>Sum</b>	<b>52</b>	<b>53</b>	<b>51</b>	<b>45</b>	<b>39</b>	<b>33</b>	<b>27</b>	
<b>NC 41</b>	<b>RC 39(N)</b>		<b>47 dBA</b>					

### Path1

Custom Element	106	107	106	100	96	91	87	
Outdoor	-49	-49	-49	-49	-49	-49	-49	CT-2
Barrier	-5	-5	-6	-7	-8	-10	-12	Barrier insertion loss
<b>Sum</b>	<b>52</b>	<b>53</b>	<b>51</b>	<b>44</b>	<b>39</b>	<b>32</b>	<b>26</b>	
<b>NC 41</b>	<b>RC 38(N)</b>		<b>46 dBA</b>					

### Path3

Custom Element	106	107	106	100	96	91	87	
Outdoor	-50	-50	-50	-50	-50	-50	-50	CT-3
Barrier	-5	-5	-6	-7	-8	-10	-12	Barrier insertion loss
<b>Sum</b>	<b>51</b>	<b>52</b>	<b>50</b>	<b>43</b>	<b>38</b>	<b>31</b>	<b>25</b>	
<b>NC 40</b>	<b>RC 37(N)</b>		<b>45 dBA</b>					

### Path4

Custom Element	106	107	106	100	96	91	87	
Outdoor	-50	-50	-50	-50	-50	-50	-50	CT-4
Barrier	-5	-5	-6	-7	-9	-11	-13	Barrier insertion loss
<b>Sum</b>	<b>51</b>	<b>52</b>	<b>50</b>	<b>43</b>	<b>37</b>	<b>30</b>	<b>24</b>	
<b>NC 40</b>	<b>RC 37(N)</b>		<b>45 dBA</b>					

COOLING TOWERS CT-1, AND CT-2 ACTIVE NORTH OF 102ND STREET.

## Paths Report

Project Name:  
Location:  
Building Owner:  
Project ID:

### Path2

Element	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	Comments
Custom Element	106	107	106	100	96	91	87	CT-1 Barrier insertion loss
Outdoor	-49	-49	-49	-49	-49	-49	-49	
Barrier	-5	-5	-6	-7	-8	-10	-12	
Sum	52	53	51	44	39	32	26	
NC 41	RC 38(N)		46 dBA					

### Path1

Custom Element	106	107	106	100	96	91	87	CT-2 Barrier insertion loss
Outdoor	-49	-49	-49	-49	-49	-49	-49	
Barrier	-5	-5	-6	-6	-8	-9	-11	
Sum	52	53	51	45	39	33	27	
NC 41	RC 39(N)		47 dBA					

COOLING TOWER CT-1 ACTIVE NORTH OF 102ND STREET.

## Paths Report

Project Name:

Location:

Building Owner:

Project ID:

### Path2

Element	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	Comments
Custom Element	106	107	106	100	96	91	87	CT-1 Barrier insertion loss
Outdoor	-49	-49	-49	-49	-49	-49	-49	
Barrier	-5	-5	-6	-7	-8	-10	-12	
Sum	52	53	51	44	39	32	26	
NC 41	RC 38(N)		46 dBA					