

Building plans must be signed by a MN licensed architect.

Must meet 2020 MN State Building Code

Must meet 2020 MN Accessibility Code.

SAC review by MET council will be required.

Provide a detailed code analysis with the plans.

For secondary address contact Bruce Bunker, bbunker@bloomingtonmn.gov or 952-563-4546.

The entire space shall be fully sprinklered.

The entire space shall have a code compliant fire alarm system.

There doesn't appear to be a connection between the school and theater. Will that create issues for the operation?

Be sure to accommodate space for trash and recycling within the building

