

Building plans must be signed by a MN licensed architect.

Must meet 2020 MN State Building Code.

Must meet 2020 MN State Accessibility Code.

SAC review by MET council will be required.

Provide detailed code analysis with the plans.

For secondary address contact Bruce Bunker, bbunker@bloomingtonmn.gov or 952-563-4546.

The entire space shall be fully sprinklered.

The entire space shall have a code compliant fire alarm system.

Stage curtains and other similar materials/textiles shall be approved by Building and Fire prior to installation.

Be sure to accommodate space for trash and recycling within the building

Provide an Environmental Health Plan Review application with plan submittal for each proposed food facility.

Provide equipment specification sheets on any proposed equipment to be used in kitchen.

