



# Comment Summary

**Application #:** PL202200118  
**Address:** 501 W 98TH ST, BLOOMINGTON, MN 55420  
**Request:** Conditional use permit for an outdoor patio for an existing restaurant  
**Meeting:** Planning Commission - July 14, 2022

---

**NOTE: All comments are not listed below.**  
**Please review all plans for additional or repeated comments.**

**Planning Review Contact:** Elizabeth O'Day at [oday@BloomingtonMN.gov](mailto:oday@BloomingtonMN.gov), (952) 563-8919

- 1) The sidewalk must maintain a five-foot unobstructed width.

**Building Department Review Contact:** Kelly Beyer at [kbeyer@BloomingtonMN.gov](mailto:kbeyer@BloomingtonMN.gov), (952) 563-4519

- 1) A Building permit is required. SAC determination is also required - apply through the Met Council.

**Environmental Health Review Contact:** Erik Solie at [esolie@BloomingtonMN.gov](mailto:esolie@BloomingtonMN.gov), (952) 563-8978

- 1) No exterior storage of any plates, silverware, food or other food items on tables outside. Tables must be set once customer sits down to eat.

**Fire Department Review Contact:** Laura McCarthy at [lmccarthy@BloomingtonMN.gov](mailto:lmccarthy@BloomingtonMN.gov), (952) 563-8965

- 1) Insure tables and chairs don't impede egress from the restaurant.

**Clerk's Office Review Contact:** Doug Junker at [djunker@BloomingtonMN.gov](mailto:djunker@BloomingtonMN.gov), (952) 563-4923

- 1) Must apply for an amendment to the wine and beer license to include the patio. Submit a drawing, with measurements, with the request to Doug Junker.