

Type I hood required with a suppression system connected to the sprinkler system.

Kitchen

1001

PL201700051
PL2017-51

Provide full layout of space on the building plans submitted.

Will require Accessible bathrooms. 1 Female, 1 Male.

2200 sf

Dinning - Room

2 sets of paper plans must be submitted to scale for review. Once 50 occupants are involved 2 clear exits are required and the doors must swing out not in. Exits may not go through kitchen areas.

2200 sf

*9066 Lyndale Ave. S
Bloomington, MN*

46-50 seats

A SAC review will be required prior to building permit issuance.

EAT GREEK