



## Comment Summary

**Application #:** PL2018-119

**Address:** 4001 W 102ND ST, BLOOMINGTON, MN 55437

**Request:** Final Site and Building Plans for exterior modifications, adding an elevator tower

---

**NOTE: All comments are not listed below. Please review all plans for additional or repeated comments.**

**Planning Review Contact:** Elizabeth O'Day at eoday@BloomingtonMN.gov, (952) 563-8919

- 1) Revised landscaping plan required.

**Building Department Review Contact:** Duke Johnson at djohnson@BloomingtonMN.gov, (952) 563-8959

- 1) Building permit required for addition- 2 Hr shaft enclosure
- 2) Elevator Permit required by State of MN

**Fire Department Review Contact:** Laura McCarthy at lmccarthy@BloomingtonMN.gov, (952) 563-8965

- 1) Detection and recall functions shall report to/through the building fire alarm panel.
- 2) Addition shall not interfere with access to FDC