



Comment Summary

Application #: PL201800195

Address: 7101 West 78th Street, Bloomington, MN 55439

Request: **Minor Revision to Final Site and Building Plans to widen a drive aisles and install parking lot islands.**

NOTE: All comments are not listed below. Please review all plans for additional or repeated comments.

Planning Review Contact: Nick Johnson at nmjohnson@BloomingtonMN.gov, (952) 563-8925

- 1) Parking island design from approved site plan in Case #09645B-97.

Fire Department Review Contact: Laura McCarthy at lmccarthy@BloomingtonMN.gov, (952) 563-8965

- 1) Maintain 3-foot clear around existing hydrant, ensuring visibility and availability for use.