



Comment Summary

Application #: PL201800317

Address: 8201 Park Avenue South, Bloomington, MN 55420

Request: **Final Site and Building Plans to construct a driveway from the existing western parking lot to East 83rd Street.**

NOTE: All comments are not listed below. Please review all plans for additional or repeated comments.

Planning Review Contact: Nick Johnson at nmjohnson@BloomingtonMN.gov, (952) 563-8925

- 1) Minimum drive aisle width is 20 feet per the Fire Code.

Building Department Review Contact: Bernadette Gillespie at bgillespie@BloomingtonMN.gov, (952) 563-4709

- 1) A parking lot permit must be obtained prior to construction.

Fire Department Review Contact: Laura McCarthy at lmccarthy@BloomingtonMN.gov, (952) 563-8965

- 1) Maintain emergency vehicle access and circulation throughout the property.