



Comment Summary

Application #: PL201900115

Address: 7801 COMPUTER AVE S AND 7850 NORD AVENUE, BLOOMINGTON, MN 55435

Request: Add a vestibule to gate 10 at the Bloomington campus

NOTE: All comments are not listed below.
Please review all plans for additional or repeated comments.

Planning Review Contact: Elizabeth O'Day at coday@BloomingtonMN.gov, (952) 563-8919

- 1) EIFS is a secondary material and allowed no more than 15% of an elevation.
- 2) lighting must be 90 degree cutoff and provide at least 2 FC.

Building Department Review Contact: Duke Johnson at djohnson@BloomingtonMN.gov, (952) 563-8959

- 1) Must meet MN Accessibility Code
- 2) Must meet current MN State Building Code

Public Works Review Contact: Brian Hansen at bhansen@BloomingtonMN.gov, (952) 563-4543

- 1) All construction and post-construction parking and storage of equipment and materials must be on-site.
 Use of public streets for private construction parking, loading/unloading, and storage will not be allowed.