



Comment Summary

Application #: PL2019-123

Address: 1700 American Boulevard East, Bloomington, MN 55425

Request: Uniform Sign Design Amendment for Great Wolf Lodge.

NOTE: All comments are not listed below.
Please review all plans for additional or repeated comments.

Planning Review Contact: Nick Johnson at nmjohnson@BloomingtonMN.gov, (952) 563-8925

- 1) These signs should be identified as incidental signs, not directional signs. Incidental signs are limited to 12 square feet in size (Sec. 19.117(b)).
- 2) For freestanding directional signs, you must include sign height in addition to sign area.
- 3) This directional sign is attached to slide support structure, is that correct? Please confirm and include this information, mounting height, etc.