



Comment Summary

Application #: PL201900218
Address: 2051 KILLEBREW DR, BLOOMINGTON, MN 55425
Request: **Conditional Use Permit for BlueSky Online School at 2051 Killebrew Dr**
Meeting: Pre-Application DRC – October 29, 2019
Planning Commission – December 19, 2019
City Council - January 06, 2020

**NOTE: All comments are not listed below.
Please review all plans for additional or repeated comments.**

Planning Review Contact: Shawn James at sjames@BloomingtonMN.gov, (952) 563-8918

- 1) List the number of parking spaces required by city code and the number of spaces provided on the site plan. (Section 21.301.06)
- 2) Exterior security lighting must meet Section 21.301.07. Must show lighting compliance for the required number of parking spaces.

Fire Department Review Contact: Laura McCarthy at lmccarthy@BloomingtonMN.gov, (952) 563-8965

- 1) The entire space to be sprinklered.
- 2) Fire alarm audible/visual devices required throughout.

Public Works Review Contact: Brian Hansen at bhansen@BloomingtonMN.gov, (952) 563-4543

- 1) Show location of a bike rack and bike rack detail on the plan.
- 2) List the number of parking spaces required by city code and the number of spaces provided on the site plan.