



Comment Summary

PL201600185

Application #: PL201600185

Address: 7803 PENN AVE S, Unit:, BLOOMINGTON, MN 55431.

Request: **Minor Revision to Final Development Plans to install two small cell wireless installations on light poles at Southtown Shopping Center.**

Planning Review Contact: Nick Johnson at nmjohnson@BloomingtonMN.gov, (952) 563-8925

1) Parking lot lighting must meet the requirements of Sec. 21.301.07 of the City Code.
Photometric plans must be reviewed and approved prior to the issuance of a building permit.

Building Department Review Contact: Bernadette Gillespie at bgillespie@BloomingtonMN.gov, (952) 563-4709

1) Must meet 90MPH wind rating per MN State Building code

Utility Review Contact: Jen Desrude at jdesrude@BloomingtonMN.gov, (952) 563-4862

1) See Plan markups regarding separation distances from existing utilities and utility appurtenances.