




Building plans must be signed by a MN licensed architect.

SAC review by MET council will be required.

According to applicant, Suite B is 13,780 sq ft. Plan is not clear.



Must meet 2020 MN State Building Code

Must meet 2020 MN Accessibility Code

Provide a code analysis with the plans.