



Comment Summary

Application #: PL202200136

Address: 3 & 4 APPLETREE SQUARE, BLOOMINGTON, MN 55425

Request: Major revisions to previously approved final development plans for the Aire Apartments located at 3 & 4 Appletree Square

Meeting: Planning Commission - July 28, 2022
City Council - August 08, 2022

NOTE: All comments are not listed below.
Please review all plans for additional or repeated comments.

Fire Department Review Contact: Laura McCarthy at lmccarthy@BloomingtonMN.gov, (952) 563-8965

- 1) Fire alarm devices, smoke alarms and CO alarms to be upgraded for occupancy type including low frequency devices in the units.
- 2) Code complying sprinkler protection throughout.
- 3) Kitchen hoods to be protected by code complying suppression system connected to the building sprinkler system.
- 4) Any locked stairwell or access doors shall unlock on a general fire/water flow alarm and by manual means at the FAC panel.