



Comment Summary

Application #: PL202200118
Address: 501 W 98TH ST, BLOOMINGTON, MN 55420
Request: Conditional use permit for an outdoor patio for an existing restaurant
Meeting: Planning Commission - July 14, 2022

NOTE: All comments are not listed below.
Please review all plans for additional or repeated comments.

Planning Review Contact: Elizabeth O'Day at oday@BloomingtonMN.gov, (952) 563-8919

- 1) The sidewalk must maintain a five-foot unobstructed width.

Building Department Review Contact: Kelly Beyer at kbeyer@BloomingtonMN.gov, (952) 563-4519

- 1) A Building permit is required. SAC determination is also required - apply through the Met Council.

Environmental Health Review Contact: Erik Solie at esolie@BloomingtonMN.gov, (952) 563-8978

- 1) No exterior storage of any plates, silverware, food or other food items on tables outside. Tables must be set once customer sits down to eat.

Fire Department Review Contact: Laura McCarthy at lmccarthy@BloomingtonMN.gov, (952) 563-8965

- 1) Insure tables and chairs don't impede egress from the restaurant.

Clerk's Office Review Contact: Doug Junker at djunker@BloomingtonMN.gov, (952) 563-4923

- 1) Must apply for an amendment to the wine and beer license to include the patio. Submit a drawing, with measurements, with the request to Doug Junker.