



## Comment Summary

**Application #:** PL201700150

**Address:** 1700 American Boulevard East, Bloomington, MN 55425

**Request:** **Uniform Sign Design (USD) Amendment for a hotel. (USD 181)**

---

**Planning Review Contact:** Nick Johnson at nmjohnson@BloomingtonMN.gov, (952) 563-8925

- 1) Maximum sign illumination of proposed wall signs is 300 nits.
- 2) Elevations of the hotel should be designated as primary or secondary for the purposes of wall signage allowance according to Section 19.121(b)(2)(A) of the City Code.