

Twin City Water Clinic, Inc.

617 13th AVE. SO.

HOPKINS, MINNESOTA 55343

935-3556

Stodola Well Drilling
15306 Highway 7
Minnetonka, Mn. 55345

January 15, 1990

REPORT OF WATER ANALYSIS

Our laboratory reports these analytical results, determined on a sample (received from you) ~~at~~ on December 29, 1989

Well water
from
Micron Molding
101 W. 79th St.
Bloomington, Mn.

Unique Well # 505073

Bacteria (Coliform group)	less than 1/100 ml
Nitrate nitrogen	less than 0.1 mg/l
Conductivity, Specific	480. micromhos

The results of these tests indicate that this well is producing water that meets the standards for F.H.A., V.A., or conventional loans.

Twin City Water Clinic, Inc.

Bill Van Arsdale

Analytical laboratory
Water analysis reagents

Consulting engineer
Boiler water chemicals