



Protecting, Maintaining and Improving the Health of All Minnesotans

Division of Environmental Health
PLAN REVIEW APPROVAL

Plans and specifications on watermain: Luther Bloomington Kia, Bloomington, Hennepin County,
Plan No. 250238, PWSID 1270001

OWNERSHIP: Bloomington City Council, c/o Ms. Christina Scipioni, City Clerk, Bloomington City Hall,
1800 West Old Shakopee Road, Bloomington, Minnesota 55431-3027

SUBMITTER(S): Landform Professional Services, LLC, c/o Steve Sabraski, 105 South Fifth Avenue,
Minneapolis, Minnesota 55401

Linda McGinty, 3701 Alabama Avenue South, St. Louis Park, Minnesota 55416

Date Received: November 20, 2024

Date Reviewed: November 26, 2024

APPROVAL: Based on the information provided to the Minnesota Department of Health (MDH) for review, this project is approved, contingent upon the project meeting all of the requirements listed below. Construction must be according to the plans and specifications provided to MDH.

LIMITED SCOPE: This review is limited to the project design's effect on the safety and sanitary quality of the drinking water and assumes the data on which the design is based are correct. Examination is based on MDH rules and applicable standards. This report applies to this project only, and not to any additional parts of the water system. The project designer is responsible for the project's features and equipment effectiveness.

ALTERATIONS: MDH must approve any changes that deviate from the approved plans before any changes are made. Otherwise, the construction will be considered installed without proper approval.

INSPECTIONS: It is the responsibility of the owner or owner's agent to arrange for any inspections that are listed in the requirements of this report. **The project owner must retain the plans at the project location.**

This project consists of the installation of the following watermain:

1. 338 lineal feet of 6-inch DIP watermain.
2. 932 lineal feet of 8-inch DIP watermain.

Luther Bloomington Kia
PWSID 1270001
Watermain
Plan No. 250238
Page 2
December 4, 2024

Requirement(s):

1. It is understood that the installation of the watermain will be in accordance with previously approved specifications for the city of Bloomington, Minnesota.
2. It is understood that the installation will be in accordance with previously approved City Engineers Association of Minnesota Watermain Specifications, 2023 edition
3. Verify that adequate freeze protection is provided, especially between watermain and storm sewers or catch basins. (10 States Standards 8.7.3)


The approval is valid for two years from the date of this letter. If project construction has not begun within the two-year period, plans and specifications must be resubmitted to MDH for approval before any construction takes place. While the project has been contingently approved, changed conditions or additional information may result in additional requirements.

If you have any questions regarding information contained in this report, please contact me at 651-201-5309 or jack.smude@state.mn.us.

Approved:



Jack Smude
Public Health Engineer
Section of Drinking Water Protection
P.O. Box 64975
St. Paul, Minnesota 55164-0975



Alex H. Bartley, P.E.
Public Health Engineer
Section of Drinking Water Protection
P.O. Box 64975
St. Paul, Minnesota 55164-0975

AHB:JS:jh

cc: Steve Sabraski, Landform Professional Services, LLC
Linda McGinty